

Lampedusa Office Building is surrounded by many transportation lines (Tram, Bus and Metro) and a lot of facilities that help in making this area like the Porta Nuova district in the future like (Restaurants, Hotels, Green Areas, Supermarkets, Post office, School)




- Buildings
- Green Areas
- Selected Area
- Post Office
- Office Building
- Restaurant
- School
- Sports Center
- Church
- Car services
- Super Market
- Bus station
- Tram station
- Metro station



- The Selected Area
- Green Areas
- Street
- Warm Wind
- Cold Wind
- Spring Wind
- Winter Radiation
- Summer Radiation

The Map showing the Wind direction and speed around the selected area for the Lampedusa Office Building over the year as the Prevailing Wind are from (West South West, South West, East South East and East), and also showing the Summer Radiation and Winter Radiation



Lampedusa Office Building is located in Milan, "at latitude 45°26'04.42" N and longitude 9°11'26.49" E"

And it is the extended Line Axis for: "Duomo Cathedral" "Porta Nuova Business District"



1 Porta Nuova Business District





2 Duomo (Milan city center





3 Lampedusa Office Building

PSYCHROMETRIC Chart for the Building Showing the Building Climate during "Summer Season"



PSYCHROMETRIC Chart for the Building Showing the Building Climate during "Winter Season"





Site Plan
Scale (1/500mm)

Ground Floor Plan
Scale (1/200mm)



Under Ground Floor Plan
Scale (1/200mm)

First Floor Plan
(First Level :Seventh Level)
Scale (1/200mm)

Several Shots for The Existing Building




View (3)

View (2)



Several 3D Shots for the Existing Office Building , showing the Facades with its materials cladding and showing also, the service stairs

"Key Plans"



- LEGEND
- Empty Floor
 - Offices/Work Spaces
 - Vertical Circulation
 - Toilets
 - Entrance
 - Corridor
 - Parking



"Key Section (A-A)"



Section (A-A)
Scale (1/200mm)




Heat Pump System "Decreasing Energy Consumption"




Heat Pump will be connected to the solar chimney in the building, as in Winter convert the cold air to warm air and in the Summer convert warm air to cold air, and this system decrease the Energy Consumption

PCM "Phase Change Material" "Thermal Comfort" (in Ceiling)



PCMs can be used in several ways, such as Thermal energy storage whereby heats, or Coolness, that can be stored from one process or period and used later, also very useful in providing Thermal barriers or insulation

Thermal Insulation



Reduce the heat transfer between objects in thermal contact or in range of radiative influence, it can be achieved with specially engineered methods or processes, as well as with suitable materials

Cooling

Vertical Sunshades "Sun Protection" [South West & South East]




Use louvers in stade of solid overhang for more diffuse light while still shading

Operable Windows "Cross Ventilation" "Inlet openings(South West & South East)" "Outlet openings(North West & North East)"




To make air movement inside the building as "Cross Ventilation" to enhance the Natural ventilation

Solar Chimney "Stack Ventilation" [South West]



Postive pressure pushes air out of windows, seams and cracks on the upper levels as Negative pressure on lowels levels encourages infiltration of cold outdoor air through openings

Double Glass "Reduction Heat Loss" [All Facades]



Using Double glass as it's "U-value" is lower than Single glass

Lighting

SkyLight [Nouth East]




Filtrating the air inside the building, Making a natural atmosphere to enhance the the inspiration of the employees and Feeling Comfortable during the working hours

LED Lighting System "Reduce Energy Consumption"

	standard incandescent	CFL compact fluorescent lamp	LED
watts >>	60	18	10
lumens >>	840	825	800
life (years) >>	0.9	9.1	22.8
estimated annual energy cost* >>	\$7.23	\$5.18	\$1.56
Initial cost per bulb >>	\$2.00	\$8.00	\$12.00

Using the LED lighting system as this system has life spa n more than any other system, it is the lowest cost and decrease the Energy Consumption for the Building







Site Plan Scale (1/500mm)



Ground Floor Plan Scale (1/200mm)



Second Floor Plan (First Level:Seventh Level) Scale (1/200mm)




Under Ground Floor Plan Scale (1/200mm)



First Floor Plan Scale (1/200mm)

"Key Plans"



First Level to Seventh Level

Ground Level

Under Ground Level



The Terrace(Open space) for employees to have more Natural Atmosphere inside the building




The Atrium inside the building as it will be the Rest Area for employees (for coffee and taking a break), and also for Direct Light

LEGEND

- Atrium
- Vertical Circulation
- Toilets
- Corridor
- Directors Offices
- Open Offices
- Open Terrace
- Services
- Security
- Secretary
- Manager Office
- Meeting Room
- Computers Lab
- Technician Office
- Conference Room
- Storage
- Archive Offices
- Parking

"Key Section (A-A)"




"Key Section (B-B)"

- Second Level
- First Level
- Ground Level
- Under Ground Level




The Horizontal Sunshades in the (South East & South West) Facades



The Horizontal Sunshades Detail Scale (1/10mm)


Section (A-A) Scale (1/200mm)




The Green Roof Detail Scale (1/10mm)



The Green Roof and the Skylight on the Roof of the Building




The Skylight Detail Scale (1/10mm)




The Curtain Wall Detail Scale (1/10mm)




The Curtain Wall Facade and the View of the Atrium that inside the Building




Section (A-A) Scale (1/200mm)



The Operable Window Detail Scale (1/10mm)



Section (B-B) Scale (1/200mm)



1 The North East Facade

2 The North West Facade



3 The South West Facade

4 The South East Facade



The Rest & Green area and its connection with the Vertical services



The Rest & Green area with the Atrium and Natural light



The Entrance of the Office Building with the Atrium and The Green Area



The offices (Open Work Space) inside the Building with The Natural light

Interior Shots





The Overview for the Proposed Office Building with Surrounded Site



The Intervention of Renovate a Service Stairs to work as Solar Chimney in the South West Facade




The Intervention of Adding Atrium with Skylight in the North East Facade

The Intervention of Renovate the Empty Terrace to be as Vegetation Terrace that surrounded by North East & North West & South West Facades

The Intervention of Renovate the Empty Corridor to be as a Part of the Ground Floor in the North East Facade

The 3D Section Plan for The Ground Floor



Operable Windows

Operable Window "AWS 114" from Schüco

ELEMENT	MATERIAL	THERMAL CONDUCTIVITY (W/mK)
Frame Detail	Aluminium Anodized	$\lambda = 160$
Gaskets	EPDM	$\lambda = 0.25$
Glazing	Laminated Glass Thermal Glass Float Glass	$\lambda = 0.75$ $\lambda = 1$ $\lambda = 1$
Spacer	Polyisobutylene Butyl Rubber Silica Gel Bulk Aluminium Anodized	$\lambda = 0.4$ $\lambda = 0.24$ $\lambda = 0.13$ $\lambda = 160$
Insulation	Polyamide 6.6 with 25% Glass Fiber	$\lambda = 0.3$
Insulation Panel	Polyurethane Foam	$\lambda = 0.05$
Gasket Element	Silicone Foam	$\lambda = 0.17$
Sub Frame	PVC(ripid)	$\lambda = 0.17$
Tab Frame	Galvanized Steel	$\lambda = 0.2$
Sealant	Silicone	$\lambda = 0.35$
Insulation Panel		$\lambda = 0.035$

Vertical Section

Frame + Glass	Frame + Insulation Panel		
Total Length	Projected (X)		
FRAME	EDGE		
U	1.48	1.22	
b	0.17	0.29	
L_{eq}^{1D}	Ψ	0.518	0.129

The calculations of (U. Value) for Frame and Edge

Horizontal Section (Transparent Part)

Frame + Glass	Frame + Insulation Panel		
Total Length	Projected (X)		
FRAME	EDGE		
U	1.4	1.1	
b	0.12	0.2	
L_{eq}^{1D}	Ψ	0.477	0.111

The calculations of (U. Value) for Frame and Edge

Horizontal Section (Opaque Part)

Frame + Glass	Frame + Insulation Panel		
Total Length	Projected (X)		
FRAME	EDGE		
U	1.4	1.1	
b	0.12	0.2	
L_{eq}^{1D}	Ψ	0.477	0.111

The calculations of (U. Value) for Frame and Edge

The Final Results of (U-value calculations)

$$U_{W} = \frac{U_{glass}A_{glass} + U_{frame}A_{frame} + \sum \Psi_i L_i}{A_{TOT}}$$

- U_{glass} = 0,9 W/m²K (from data sheet)
- U_{frame} = 1 W/m²K (from data sheet)
- Ψ = linear thermal transmittance.
- A_{TOT} = total area of the window, obtained as sum of the area of all the element of the window
- U_W = total thermal transmittance of the window

A _o m ²	U _o W/m ² K	A _r m ²	U _r W/m ² K	L _r m	Ψ W/mK	L _r m	Ψ W/mK	A _{TOT} m ²	U _W W/m ² K	U _{W(TOTAL)} W/m ² K
0.98	0.9	0.62	1	1.4	0.11	1.14	0.13	1.6	1.14	1.4

The U_W = 1,14 W/m²K which is < 1,4 the limit assigned by UNI EN 13830:2015, so the unit of the window verified the standard limit values
Inner Temperature higher than the Dew point, so there is no condensation of the Window

Double Glazing Curtain Wall "UC 65" from Schüco

ELEMENT	MATERIAL	THERMAL CONDUCTIVITY (W/mK)
Frame Detail	Aluminium Anodized	$\lambda = 160$
Sealant	Silicone	$\lambda = 0.35$
Gaskets	EPDM	$\lambda = 0.25$
Glazing	Glass Toughened	$\lambda = 1$
Insulation	Polyamide 6.6 with 25% glass fiber	$\lambda = 0.3$
Spandrel Insulation	Rock Wool	$\lambda = 0.038$
Plasterboard		$\lambda = 0.285$
Spacer	Polyisobutylene Butyl Rubber Silica Gel Bulk Aluminium Anodized	$\lambda = 0.4$ $\lambda = 0.24$ $\lambda = 0.13$ $\lambda = 160$
Slab	Gypsum Board Aluminium Painted	$\lambda = 0.2$ $\lambda = 160$
Roof Joint	Garnul Polyethylene HD Polyethylene LD Polypropylene Polyolefin Insulation Fiber Cement Concrete Galvanized Plate Steel Polyurethane Foam Polyurethane Foam Sprayed	$\lambda = 0.7$ $\lambda = 0.5$ $\lambda = 0.33$ $\lambda = 0.22$ $\lambda = 0.18$ $\lambda = 0.031$ $\lambda = 0.6$ $\lambda = 0.85$ $\lambda = 62$ $\lambda = 17$ $\lambda = 0.05$ $\lambda = 0.024$

Vertical Section

Frame + Glass	Frame + Insulation Panel		
Total Length	Projected (X)		
FRAME	EDGE		
U	1.75	1.57	
b	0.22	0.35	
L_{eq}^{1D}	Ψ	0.943	0.46

The calculations of (U. Value) for Frame and Edge

Horizontal Section

Frame + Glass	Frame + Insulation Panel		
Total Length	Projected (X)		
FRAME	EDGE		
U	3.61	1.15	
b	0.54	0.53	
L_{eq}^{1D}	Ψ	1.251	-0.788

The calculations of (U. Value) for Frame and Edge

The Summary of The Study

The following data that already exist in the data sheet and the results from THERM, are used to calculate the overall thermal transmittance of the unitized unit:

Area m ²	U-value W/m ² K
A _g = 2.2	U _g = 1
A _r = 1.16	U _r = 0.241
A _s = 0.23	U _s = 1.93
A _{sp} = 0.17	U _{sp} = 1.89
A _{pl} = 4.76	

Length (m)	Glazing	Spandrel	(Glass-Spandrel)
L _{mg}	2.57	0.93	1.25 m
Linear Thermal Transmittance (W/mK)	U _{mg} = 1.16	U _{mp} = -0.78	U _{spg} = 0.46

The U_{cw} = 1,184148 W/m²K which is < 1,4 the limit assigned by UNI EN 13830:2015, so the unit of the curtain wall verified the standard limit values
Inner Temperature higher than the Dew point, so there is no condensation of the Curtain Wall

The Connections

Roof Joint

The inner temperatures are in between green and red on the infrared diagram. Lower temperature on the interior side in the green region is equal to 10.5 °C which is > 9.5 °C, so no condensation occurs

Slab Joint

The inner temperature values are in between green and red on the infrared diagram. Lower temperature on the interior side in the green region is equal to 11.5 °C which is > 9.5 °C, so no condensation occurs.

Vertical Connection between Window and Wall

The inner temperature values are in between green and red on the infrared diagram. Lower temperature on the interior side in the green region is equal to 10.3 °C which is > 9.5 °C, so no condensation occurs.

Horizontal Connection between Window and Wall

The inner temperature values are in between green and red on the infrared diagram. Lower temperature on the interior side in the green region is equal to 10.3 °C which is > 9.5 °C, so no condensation occurs.

SUN SHADING DEVICES

(Sun Shading Device) "Large Louvre Blades ALB - passive" from Schüco

The Tilted Angle of the Lamellas has been changed along the simulations:
"U-value, the Solar Factor and the Solar Heat gain decrease with the closing of the Lamellas"
So, the best solution is , Lamellas with a 45° angle Since as this solution is the best one to guarantee Thermal Performance of the Window and Daylight standard for the Office Building along the whole year

U Factor	SC	SHEC	Rad.Ht.Gain	T _{int}	U _g	U _{frame}	U _{sp}	U _{pl}	U _{pl}	U _{pl}	U _{pl}	U _{pl}	U _{pl}	U _{pl}	U _{pl}
0.98	0.62	0.52	229	13.6	0.903	0.903	0.903	0.903	0.903	0.903	0.903	0.903	0.903	0.903	0.903

With Shading System(Angel 45°)

U Factor	SC	SHEC	Rad.Ht.Gain	T _{int}	U _g	U _{frame}	U _{sp}	U _{pl}	U _{pl}	U _{pl}	U _{pl}	U _{pl}	U _{pl}	U _{pl}	U _{pl}
0.98	0.62	0.52	229	13.6	0.903	0.903	0.903	0.903	0.903	0.903	0.903	0.903	0.903	0.903	0.903

With Shading System(Angel 30°)

Without Shading System

Ventilated Wall

Layer	Description
1	Gypsum board + aluminium layer (vapour barrier), th. 12.5 mm
2	Gypsum board, th. 12.5 mm
3	Thermal insulation made by rockwool, th. 70 mm
4	Gypsum board, th. 12.5 mm
5	Thermal insulation made by semirigid rockwool, th. 85 mm
6	Double board of lightened concrete, with expanded polystyrene, th. 80 mm
7	Thermal insulation made of rigid polystyrene, th. 12.5 mm
8	Board of lightened concrete, with expanded polystyrene, th. 12.5 mm
9	Ventilated cavity, th. 50 mm
10	Frame
11	Cladding: green wall panels (th. 80 mm)
12	Cladding: wooden panels (th. 20 mm)

The graph shows:
X-axis there's the Equivalent Air Thickness (cm),
Y-axis the Vapor Pressure (Pa)
The Orange line is the Saturation Pressure profile, while the Blue one is the Partial Pressure profile
"Since the Partial Pressure is always smaller than the Saturation Pressure, there's no condensation"

Thermal Energy Storage (PCM)

(PCM product) "ANDOR-O-BP/58" from ebtextiles

Comparing between two cases during occupation period as following:

(Discomfort Time Percentage Index **DTP**, Weighted Discomfort Index **I.D.**, Mean Indoor Air Temperature **M.T.**, Deviation standard and Maximum Indoor Air Temperature **MAX.T.**)

City	Ventilation System	DTP (%)	I.D. [°C]	M.T. [°C]	Dev. St. [°C]	Max T. [°C]
Milano	NVS	22	149	26.4	2.0	31.0
	NVS+PCM(external)	11	33	25.4	1.9	29.7

The difference between the two cases is appreciable in all the considered parameters:
Mean Indoor Air Temperature is around a 1°C
DTP reduce to 11%
That means "The Peak Cooling Loads are Reduced for using PCM"

The Summary of The Study

Sunshades protect the building from warm rays in summer & not blocking it in winter
Skylight and Atrium increase Natural Light and filtering the air
Inlet (south-east) and Outlet (north-west) as the inlet smaller than the outlet to increase the air movement inside the building

Green Roof reflect the solar radiation and decrease the solar gain
Solar Chimney make Air rises to upper levels as it warms and increases positive pressure
"Day" PCM absorbs heat if temperature is higher than target
"Night" PCM releases heat if temperature is lower than target

Using Double glass low E with Argon filled as it's "U-value" is lower than Single glass

ISOLPARMA ENERGY PROGRAMME

heat energy demand: 45.3 kWh/(m² month)
cooling demand: 14.4 kWh/(m² month)

Energy Flow diagram for Cooling:
Heat removed from the building (cooling demand): 50.4 kWh/(m² month)
Heat removed from transport: 28.8 kWh/(m² month)
Primary energy demand: 45.3 kWh/(m² month)
End energy demand for cooling: 14.4 kWh/(m² month)
Waste heat from cooling system: 14.4 kWh/(m² month)

Surplus transmission gains: 2.1 kWh/(m² month)
ventilation gains: 0.2 kWh/(m² month)
solar gains: 41.4 kWh/(m² month)
internal gains: 6.7 kWh/(m² month)

CASANGVA ENERGY PROGRAMME

heat energy demand: 27.7 kWh/(m² month)
cooling demand: 9.1 kWh/(m² month)

Energy Flow diagram for Cooling:
Heat removed from the building (cooling demand): 23.1 kWh/(m² month)
Heat removed from transport: 18.5 kWh/(m² month)
Primary energy demand: 27.7 kWh/(m² month)
End energy demand for cooling: 9.1 kWh/(m² month)
Waste heat from cooling system: 9.1 kWh/(m² month)

Surplus transmission gains: 0.3 kWh/(m² month)
ventilation gains: 0.2 kWh/(m² month)
solar gains: 18.4 kWh/(m² month)
internal gains: 4.2 kWh/(m² month)

(The Existing Office Building):
Heating Energy Demand 125 kWh/(m²a)
Cooling Energy Demand 40 kWh/(m²a)

As a result of the above Interventions (The New Proposal):
Heating Energy Demand 70 kWh/(m²a)
Cooling Energy Demand 22 kWh/(m²a)
So, Heat Energy Demand and Cooling Energy Demand will be decreased inside the Office Building more than half and also, the Total Energy Consumption decreased more than "40%" per year